Attestation of Conformity

EMC test - Certificate no. 729

Since 1992 DELTA has been appointed Competent Body by the notified authority National Telecom Agency, Denmark. The attestation of conformity with the below mentioned standards and/or normative documents is based on accredited EMC test carried out at DELTA.

DELTA client

Proces-Data A/S Navervej 8 8600 Silkeborg Denmark

Product identification (type(s), serial no(s).)

PD 340 flow transmitter

Manufacturer

Proces-Data A/S

Technical report(s)

DELTA Test Report, project no. A53047, DANAK-199767 DELTA Test Report, project no. A530047-1, DANAK-198014

Standards/Normative documents

EN 55022:1998+A1+A2 CISPR 22:1997+A1+A2 OIML R117 2CD EMC Directive 89/336/EEC

The product identified above has been assessed and complies with the specified standards/normative documents. The attestation does not include any market surveillance. It is the responsibility of the manufacturer that mass-produced apparatus have the same EMC quality. The attestation does not contain any statements pertaining to the EMC protection requirements pursuant to other laws and/or directives other than the above mentioned if any.

DELTA

Danish Electronics, Light & Acoustics

Venlighedsvej 4 2970 Hørsholm Denmark

Tel. (+45) 72 19 40 00 Fax (+45) 72 19 40 01 www.delta.dk

Hørsholm, 08 July 2005

Per Thåstrup Jensen M.Sc.E.E.

. *DELTA*



EC type-approval certificate

Number **T5151** revision 1 Project number 706265 Page 1 of 3

Issued by NMi Certin B.V.

Hugo de Grootplein 1 3314 EG Dordrecht The Netherlands

Notified Body Number 0122

In accordance

with

The Council Directive 90/384/EEC on non-automatic weighing instruments.

Applicant Proces-Data A/S

Navervej 8-10 DK-8600 Silkeborg

Denmark

In respect of A class (III) or (III), electronic non-automatic weighing instrument.

Manufacturer : Proces-Data

Type : Depending on the configuration

Characteristics $n \le the number of scale intervals mentioned in the test certificates involved$

In the description number T5151 revision 1 further characteristics are described.

Valid until 30 October 2017

Description The instrument is described in the description number T5151 revision 1,

appertaining to this EC type-approval certificate.

Remarks / This revision EC type-approval certificate replaces the earlier versions.

Dordreght, 30 October 2007

NMi Certin B.\

Ing. C. Oosterman

Manager Product Certification

Telefax +31 78 6332309

This document is issued under the provision that NMi. B.V. nor its subsidiary companies accept any liability.

Reproduction of the complete document is allowed. Parts of the document may only be reproduced after written permission.



Description

Number **T5151** revision 1 Project number 706265 Page 3 of 3

1.4 Conditional parts

The non-automatic weighing instrument may be equipped with peripheral equipment which is used for the applications listed in article 1(2)(a) of the EC Directive (90/384/EEC), if the peripheral equipment is certified to be connected to an EC type-approved non-automatic weighing instrument by a Notified Body appointed to certify non-automatic weighing instruments according to paragraph I of Annex II of the EC directive on Non-Automatic Weighing Instruments. The non-automatic weighing instrument is fitted with a levelling device and a level indicator, unless the instrument is installed in a fixed position. The level indicator has a sensitivity of at least 2 mm for a tilt of 2/1000.

1.5 Conditional characteristics

The conditional characteristics are described in the test certificates involved.

1.6 Non-essential parts

The non-automatic weighing instrument may be connected to non-essential devices, for example but not limited to bar code readers, foot switches, second display's and cash drawers, provided that:

- They do not present primary data used for purposes mentioned in article 1(2)(a) of the EC Directive (90/384/EEC) unless the "preliminary observations" in Annex 1 of this directive is satisfied.
- They do not lead to an instrument having other essential characteristics than those fixed by this type-approval document.

2 Approval conditions

See chapter 1.3, essential shapes.

3 Seals and verification marks

See chapter 1.3, essential shapes.

4 CE-mark of conformity and inscriptions

The marks, facilities for the marks and the inscriptions on the non-automatic weighing instrument fulfill the requirements of article 1 of Annex IV.



Description

Number **T5151** revision 1 Project number 706265 Page 2 of 3

1 General information about the non-automatic weighing instrument

All properties of the non-automatic weighing instrument, whether mentioned or not, may not be in conflict with the legislation.

1.1 Essential parts

Indicator:

Manufacturer	Туре	Test certificate number
Proces-Data	PD 4000 / PD 3230 PD 4000 / PD 1435	TC2409

Any load cell(s) may be used, only as described in WELMEC 2.4 Issue 2, for instruments under this EC type-approval certificate, provided the following conditions are met:

- There is a respective test certificate (EN45501) or an OIML Certificate of Conformity (R60) issued for the load cell by a Notified Body responsible for type examination under Directive 90/384/EEC.
- The certificate contains the load cell types and the necessary load cell data required for the manufacturer's declaration of compatibility of modules (WELMEC 2, Issue 4, 2004, No 11), and any particular installation requirements. A load cell marked **NH** is allowed only if humidity testing to EN45501 has been conducted on this load cell.
- The compatibility of load cells and indicator is established by the manufacturer by means of the compatibility of modules form, contained in the above WELMEC 2 document, at the time of EC verification or declaration of EC conformity of type.
- The load transmission must conform to one of the examples shown in the WELMEC guide for load cells (WELMEC 2.4 Issue 2).

1.2 Essential characteristics

The essential characteristics are described in the test certificates involved.

1.3 Essential shapes

The data plate is secured against removal by sealing or will be destroyed when removed. To secure components that may not be dismantled or adjusted by the user, the non-automatic weighing instrument has to be secured in a suitable manner on the locations indicated in the test certificates involved and the load cell cable or the junction box has to be secured. The securing component has to bear either:

- A mark of the manufacturer laid down in a notified body approved quality system (Annex II of the directive 90/384/EEC), or
- An official mark of a Member State of the EEC, or another party to the EEA agreement.